no. HDAMD/B.O. 5/410/2022

Office of Executive Engineer Hoist Design And Manufacturing Division Dapodi Pune-411012 Date- 多/3/282フ

To, M/s 1) 2)

3)

Sub:- Regarding budgetory offer for estimate purpose Supplying, installing, Testing, erection, handling etc. complete work commissioning of electrically actuated double flanged Butterfly valve and Dismantling joint of Dia. 1600mm PN 1 Rating.

Dear Sir,

In connection with the above, we are in Water Resources Department working under Govt. Of Maharashtra and are entrusted with the mechanical work On Various Dam, ETC. Sealed & Super scribed budgetory offers are invited here with for following work.

Name Of the Work:-Manufacturing, Supplying, installing, erection, testing and commissioning of electrically actuated double flanged Butterfly valve and Dismantling Joint of dia. 1800 mm PN 1 Rating- on Service Gate of project site, etc complete.

No.	Desciption	Qty	Rate	Amt.
	Budgetory rates for Design, manufacturing, providing, supplying, erection, testing, commissioning on site etc. complete job for BFV cast steel PN 1 rating of φ 1800 mm for High Water Head of Reputed Make Registered manufacturer & as per relevant standard IS 13095 code for each item requested at including design, drawing, Material details, etc. complete with standard body, shaft extended on either side, Gear mechanism for valve operation with electrical motor, ss valve seat, Hollow Disc water hammer resistant against desired water head 50 Mtr etc. complete as per requirement. With material, labour, w/s charges, sundry material, Handling charges, Machinery Charges etc.	PER NO	27	
	complete for project site.			
A)	Manufacturing specifications: - ID φ1800 mm; pipe OD 1624 mm.	-	e.,	
	1) Body :- Ductile Iron`- IS 2856:1987 Gr1			
	2) Disc :- Carbon Steel - IS 2856:1987 Gr1			
	3) Shaft :- Carbon Steel - 1570 (Parts): 1979	,		
	4) Seating ring :- Stainless Steel - IS 6603:1972			
	5) Seat :- Elastomers - E.P.D.M.Rubber			
	6) Shaft Bearing Seals: Manufactuer's Standards; suitable for duty		,	
	7) Internal fastenings: - Stainless steel - Manufacturer's standard, suitable for		-	
	duty es in			
	8) Valve Flanges(2 Nos.)			
	9) Fastner bolt ,Double Nut, Plain washer (2 Nos),Spring Washer (1nos)			
	10) Foundation Bracket			_
	11) Foundation bolts-12 Nos.			
В	de, Electric Valve Actuatoِرَ: for Double Flanged Double Eccentric Butterfly Valves of Dia. 1800 mm, PN لِلِ الْمِعْلَمِينِ for High Water Head: - Providing, erecting electric Valve actuatoှरِدِ totally enclosed, weather-proof and dust proof			
	construction, protecting class suitable for installation in any position without lubrication, leakage of other operational difficulty with special grease filled gear box and hand wheel (min. 600 mm) for emergency manual operation which will automatically disengage on restoration of power to motor.	PER NO		

С	Dismentaling Joint :- supplying, installing, testing and commissioning M.S. Dismantling joint Dia.1800 mm PN 1 Rating as per requirements including machining and rubber rings and with required flanges of suitable size with nut bolts etc complete. The joint should have through long bolts so that during normal working pressure there should be no sliding movement of sliding flanges. Length over flange should not be less than 75% of dia.Epoxy paint/Corrosion proof painting inside& outside. With all relevant IS specification, etc complete.	PER NO	
	1) Dismntal Joint Flanges(2 Nos.)		
D	2) Fastner bolt ,Double Nut, Plain washer (2 Nos),Spring Washer (1nos) Cost Of Transportation		
Е	Cost of loading & unloading	PER NO	
F	Cost of Erection at site	PER NO	
G		PER NO	
Н	Cost of inspection & Testing at factory Cost of testing & Comissioning	PER NO	

Interested contractors/ approved Vendors are requested to submit budgetory offer for above mention work duly stamped and signed by competent authority the above budgetory offer should reach to this office on or before 5 day from advertise publish.

The offer should be sent with irrigation outlet project following details specified separately for the supply details

1) Basic Price

2)Gst

3) Freight Charges

4) Discount (if any)

5)Delivery period

6) Validity of offer

Please Note Budgetory offer is invited only for the estimation purpose. It dose not give any assurance regarding floating of tender or otherwise.

Thanking You

Yours faithfully,

Executive Engineer,

Hoist Design And Manufacturing Division Dapodi Pune-411012

1) Copy submitted to Superingtending Engineer , Mechanical Cirle Pune, for information & necessary action please.

2) Copy submitted to Deputy Engineer, Hoist Manufacturing Subdivision Dapodi Pune-12, for information & necessary action .

२७ फेब्रुवारी मराठी भाषा गौरव दिन



महाराष्ट्र शासन जलसंपदा विभाग

कार्यकारी अभियंता उच्चालक संकल्पचित्र व निर्मिती विभाग दापोडी, पुणे- ४११ ०१२



दुरघ्वनी क्र ०२०-२७१४४७२०

ई मेल eehdmddpd@gmail.com

जा क्र उसंनिवि/ अंदाजपत्रकदर/ किन्य / ४१० सन २०२२ दिनांक ३.०३.२०२२

प्रति,

जिल्हा माहिती अधिकारी, जिल्हा माहिती कार्यालय, मध्यवर्ती इमारत, पुणे ४११ ००१.

विषयः - दुबार अंदाजपत्रकाकरिता दर मागविणेबाबत.क्रमांक ३ सन २०२२-२३ प्रसिध्दीस देणेबाबत. महोदय,

कृपया सोबत जोडलेली अंदाजपत्रकाकरिता दर मागविणेबाबत सूचना विस्तृत प्रसिध्दीसाठी दैनिकातून प्रसिध्दीस देण्यात यावी ही विनंती.

१) कार्यालयाचे नांव

: कार्यकारी अभियंता, उच्चालक संकल्पचित्र व निर्मिती विभाग, यांत्रिकी भवन, दापोडी, पुणे ४११ ०१२.

दुरध्वनी क्रमांक (०२०) २७१४४७२०.

२) प्रसिध्दी कोणत्या स्तरावरी करावयाची

३) वृत्तपत्रात सूचना प्रसिध्द होण्याची अंतिम तारीख

४) जाहिरातीचे बील कोणाकडे पाठवावयाचे

५) जाहिरात किती वेळा प्रसिध्द करावयाची

६) जाहिरात किती सें.मी मध्ये करावयाची

: नियमानुसार क वर्ग

दिनांक १५.०३.२०२२ किंवा तत्पुर्वी.

: कार्यकारी अभियंता, उच्चालक संकल्पचित्र व निर्मिती

विभाग, यांत्रिकी भवन, दापोडी, पुणे ४११ ०१२.

एकदाच

कमीत कमी सें.मी मध्ये करावी.

सहपत्रः - सूचना २ प्रतीत

उपकार्यकारी अभियंता उच्चालक संकल्पचित्र व निर्मिती विभाग, दापोडी, पुणे १२.

: मा. अधीक्षक अभियंता, यांत्रिकी मंडळ, पुणे - ४११ ००१ यांना माहितीसाठी सविनय सादर.

: तांत्रिक शाखा यांना माहितीसाठी रवाना. सहप्रतः - निविदा सूचना - १ प्रत.

M201211291: 192112114 31211M24