

नामकाळ

जा.क्र. 226 /उसियांत्रिक.१भ/तांशा-१/बजेटरी ऑफर/२०१६.	कार्यकारी अभियंता
फोन : (०७१८४) २५२१६६	उपसा सिंचन यांत्रिकी विभाग क्र.१, भंडारा-४४१ ९०४ यांचे कार्यालय
ई.मेल- lismech1@gmail.com	दिनांक :- २१/१२/२०१६

प्रति,

मा. अधीक्षक अभियंता,  
यांत्रिकी मंडळ,  
नागपुर.

विषय :- बजेटरी ऑफर महायांत्रिकी संकेतस्थळावर [www.mahayantriki](http://www.mahayantriki) प्रसिध्द करणेबाबत.  
बजेटरी ऑफर क्रमांक ०७ सन २०१६.

महोदय,

या पत्रासोबत पाठविण्यात येत असलेली निविदा सूचना महायांत्रिकी संकेतस्थळावर [www.mahayantriki](http://www.mahayantriki) प्रसिध्दारा देण्यात यावी. सदरहू जाहिरात विभागावस्थाराखर देण्यात यावी, ही विनंती.

१	कार्यालयाचे नांव	कार्यकारी अभियंता, उपसा सिंचन यांत्रिकी विभाग, क्र.१ भंडारा (एस.टी. जंक्शन समोर, नागपुर रोड, भंडारा).
२	बजेटरी ऑफर महायांत्रिकी संकेतस्थळावर प्रसिध्दीची अंतीम तारीख	९/०२/२०१७.


सहपत्र :- बजेटरी ऑफर प्रत्येकी २ प्रती.

कार्यकारी अभियंता,  
उपसा सिंचन यांत्रिकी विभाग  
क्र.१,भंडारा.

प्रतिलिपी :-

- १) उप अभियंता, उपसा सिंचन यांत्रिकी विभाग क्र. १/२ आंधको : यांच्या यांना माहितीकरून देण्यात येईल.
- २) उप अभियंता, उपसा सिंचन यांत्रिकी व विद्युत विभाग क्र.१, भंडारा यांना माहितीकरून देण्यात येईल.
- ३) उप अभियंता, यांत्रिकी उर्ध्वयांत्रिकी कर्मशाळा उपविभाग क्र.२, भंडारा यांना माहितीकरून देण्यात येईल.
- ४) मोटोस मोटोकर लावण्यासाठी.

RATE PROFORMA						
GOVERNMENT OF MAHARASHTRA						
WATER RESOURCES DEPARTMENT						
Budgetary Offer No. 10						
Issue Date - 03/02/2017 Closing Date - 03/02/2017						
Executive Engineer, Lift Irrigation Mechanical Division No.1, Bhandara						
Sealed Rates are invited from WRD registered contractor by the Executive Engineer, Lift Irrigation Mechanical Division No.1, Bhandara. (Phone No.07184 – 252166) for the purpose of estimation of the following works.						
Budgetary offer for Supply,Erection and Testing of new Capacitor Bank for H.T.Motor 04 Nos. for Dhapewada Lift Irrigation Scheme Dist.Gondia						
Sr. No.	Qty	Unit	Description of work	Rate Rs. P		Rates to be quoted by
1	4	Nos.	Item No.1: Capacitor Bank 6.6KV,3 Phase,50 Hz,265 KVAR : Providing,Installing at Site of works and testing of 6.6.KV ,3 Phase,50 Hz cycles per seconds new capacitor Bank for H.T.Induction motor 6.6KV,650KW and 690KW,3 Phase ,0.8PF,1000 RPM,50 Hz to improve power factor to 0.98,The KVAR capacity of the capacitor cubicles should not exceed the magnetising KVAR of Motor . Testing- The capacitor will be tested in manufacturers work as per IS 2834-1964 in the presence of the Engineer or his representative,Rate shoule be inclusive of all taxes and duties			
2	12	Nos.	Item No.2: Capacitor HRC Fuse ,6.6 KV,50 Hz,35 Amp : Providing,Installing at site of work of capacitor HRC Fuse 6.6 KV,50 Hz for above mentiones capacitor Bank.Rate should be inclusive of all taxes and duties			

  
 Executive Engineer  
 Lift Irrigation Mechanical Division No.1  
 Bhandara