

तात्काळ

जा.क्र. ४८२ /उसियांविक्र.१भं/तांशा-१/बजेटरी ऑफर/२०१९.	कार्यालय कार्यकारी अभियंता उपसा सिंचन यांत्रिकी विभाग क्र.१ भंडारा-४४१ ९०४
☎ (०७१६४) २५२१९९	
ई मेल - lismechl@gmail.com	दिनांक :- ८/३/२०१९

प्रति,

मा. अधिक्षक अभियंता
यांत्रिकी मंडळ
नागपुर

विषय :- बजेटरी ऑफर महायांत्रिकी संकेतस्थळावर www.mahayantriki प्रसिध्द करणेबाबत.
बजेटरी ऑफर क्रमांक ३६ सन २०१८-१९

महोदय,

या पत्रासोबत पाठविण्यात येत असलेली बजेटरी ऑफर महायांत्रिकी संकेतस्थळावर प्रसिध्दीस देण्यात यावी ही

विनंती.

१	कार्यालयाचे नांव	कार्यकारी अभियंता, उपसा सिंचन यांत्रिकी विभाग क्र.१, एस.टी. वर्कशॉप समोर, नागपुर रोड, भंडारा.
२	बजेटरी ऑफर महायांत्रिकी संकेतस्थळावर प्रसिध्दीची अंतीम तारीख	११/०३/२०१९

सहपत्र :- बजेटरी ऑफर - प्रत्येकी १ प्रती.

(स. सु. दाणी)
कार्यकारी अभियंता,
उपसा सिंचन यांत्रिकी विभाग क्र.१
भंडारा.

- प्रतिलिपी :- १) उप अभियंता, उपसा सिंचन यांत्रिकी उपविभाग क्र. १ आंबाडी यांना माहितीस्तव अग्रेषित.
२) उप अभियंता, उपसा सिंचन यांत्रिकी उपविभाग क्र. २ गोदिया यांना माहितीस्तव अग्रेषित.
३) उप अभियंता, उपसा सिंचन यांत्रिकी व विद्युत उपविभाग क्र.१, भंडारा यांना माहितीस्तव अग्रेषित.
सहपत्र :- बजेटरी ऑफर - प्रत्येकी १ प्रती.
४) उप अभियंता, यांत्रिकी अभियांत्रिकी कार्यशाळा उपविभाग क्र.१, भंडारा यांना माहितीस्तव अग्रेषित.
५) कार्यकारी अभियंता, उपसा सिंचन यांत्रिकी विभाग क्र.१ भंडारा यांचे कार्यालयातील नोटीस बोर्डावर लावण्यासाठी.
सहपत्र :- बजेटरी ऑफर - १ प्रतीत.
६) मा. अधिक्षक अभियंता यांत्रिकी मंडळ नागपुर यांचे कार्यालयातील नोटीस बोर्डावर लावण्यासाठी.
सहपत्र :- बजेटरी ऑफर - १ प्रती.

RATE PROFORMA
GOVERNMENT OF MAHARASHTRA
WATER RESOURCES DEPARTMENT
Budgetary Offer No. - 36 of 2018-19

Issue Date - 11/03/2019, Closing Date - 25/03/2019, Opening Date - 26/03/2019

Executive Engineer, Lift Irrigation Mechanical Division No.1, Bhandara

Sealed rates (excluding GST) are invited from WRD registered contractor by the Executive Engineer, Lift Irrigation Mechanical Division No.1, Bhandara. (Phone No.07184-252166) for the purpose of estimation of the following works.

Name of work - Repairing, overhauling & replacing of faulty devices of remote control panel, temperature scanner panel & HT panel for 07 Nos of Vertical Turbine pump at Tekepar Lift Irrigation Scheme, Tah-Bhandara, Dist-Bhandara.

Sr. No.	Description of Items	Qty	Unit	Rate
1	Item No. 1 - Remote Control Panel for 07 Nos HT motors of VT pump. Repairing, overhauling and replacing faulty devices of remote control panels with control switches, ammeter, annunciation facia windows, indication lamps etc. for control & monitoring of breakers, pump/motor ancillary equipment/panels, etc. suitable for following items and conforming to detailed specification.	1	Job	
2	Item No. 2 - HT Incomer Panel for 02 Nos. Repairing, overhauling and replacing faulty devices with control switches, ammeter, annunciation facia windows, indication lamps, breakers, etc. suitable for following items and conforming to detailed specification.	2	Job	
3	Item No. 3 - HT Buscoupler and Aux. Transformer Panel for 02 Nos. Repairing, overhauling and replacing faulty devices with control switches, ammeter, annunciation facia windows, indication lamps, breakers, etc. suitable for following items and conforming to detailed specification.	2	Job	
4	Item No. 4 - HT Panel for 04 Nos Outgoing HT motors feeder. Repairing, overhauling and replacing faulty devices of remote control panels with control switches, ammeter, annunciation facia windows, indication lamps etc. for control & monitoring of breakers, pump/motor ancillary equipment/panels, etc. suitable for following items and conforming to detailed specification.	4	Job	
5	Item No. 5 - Spares for HT panel. Spares for above item no.1,2,3&4			
	(i) Indication Lamp providing and fitting	1	Each	
	(ii) HT motor ON/OFF Switch providing and fitting	1	Each	
	(iii) HT Ammeter (0-200A, 6.6 kV) providing and fitting.	1	Each	
	(iv) Dismantling and fitting of Control cable (Control cable provided by department)	1	Meter	
	(v) Cable connector	1	LS	
	(vi) Lugs	1	LS	
	(vi) Testing of remote control panel upto HT motor feeder panel	1	Each	
6	Item No.6 - Temperature Scanner Panel. Providing, fitting and replacing faulty Temperature Scanner unit by new Temperature Scanner unit	7	Job	
7	Item No.7- Spares for Temperature Scanner Panel. Spares for above item no.6			
	(i) Checking RTD of each motor	1	Each	
	(ii) Providing and fitting of RTD with control cable (2.5*27 core control cable provided by department).	1	Each	

Note - The rate should be excluding of GST.

(S. S. Dani)
Executive Engineer
Lift Irrigation Mechanical Division No.1
Bhandara