Government of Maharashtra Water Resources Department Superintending Engineer, Mechanical Circle, Kolhapur

Budgetary offer for the following work (*Non DSR items*) are invited by the Executive Engineer, Mechanical Division, Satara-415003 Phone No. 02162-246029 on behalf of Governor of Maharashtra for estimation purpose from the reputed Manufacturers/Suppliers.

The Government of Maharashtra, Water Resources Department, has undertaken the work Providing, erection, testing and commissioning of surge protection system on rising main of Hanbarwadi LIS, Dist- Satara.

It is requested to send the budgetary offer mentioning item wise rates with rate analysis for the same & it is requested to Visit the Site Location to know the detailed nature of work. The rates should without GST and duties. The offer should reach this office on or before Dt.06.09.2021 on email./ by post/ by hand Further it is requested to forward relevant Technical literature, broachers of equipments and your comments if any.

Sr.	Work Description	Unit	Rate	Amount
No			(R s)	(R s)
01	Design, Manufacturing, Supply, Erection, Testing & Commissioning of surge protection system comprising of Bladder Vessel with volume of 5 m ³ , pressure rating 12 bar along with isolating valve, load cell arrangement, necessary piping, flanges, fasteners etc. complete ,confirming to following specifications- Connecting Pipe size - 200mm Precharge Pressure - 20m.	No		
02	Providing, supplying, commissioning of 3 stage surge suppression air valve of 100mm diameter pressure rating 12 bar on rising main with all cutting, welding of pipe for connection & necessary accessories as per site requirement. Valve should have simple and robust connection offering high reliability and free operation with high intake capacity it should be non slam surge suppression high flow combination 3 stage air valve.	No		

This information is required for the purpose of framing of working estimates and hence the urgency. This Budgetary offer is also available on website <u>www.mahayantriki.org</u> Bidder is requested to act in given time frame.

No.MDS/PB-2/Hanbarwadi /**2445**/of 2021 Office of the Executive Engineer, Mechanical Division, Krishnanagar, Satara PIN- 415003 Phone/fax No.02162/246029 e-mail <u>eemdsatara@gmail.com</u> <u>Date: 27.08.2021</u> -sd-(A.R.Kalmegh) Executive Engineer Mechanical Division, Satara

SCHEDULE

Providing, erection, testing and commissioning of surge protection system on rising main of Hanbarwadi LIS.

Sr.	Work Description	Unit	Rate	Amount
No			(Rs)	(R s)
01	Design, Manufacturing, Supply, Erection, Testing			
	& Commissioning of surge protection system	No		
	comprising of Bladder Vessel with volume of 5			
	m ³ , pressure rating 12 bar along with isolating			
	valve, load cell arrangement, necessary piping,			
	flanges, fasteners etc. complete ,confirming to			
	following specifications-			
	Connecting Pipe size - 200mm			
	Precharge Pressure - 20m			
02	Providing, supplying, commissioning of 3 stage			
	surge suppression air valve of 100mm diameter			
	pressure rating 12 bar on rising main with all			
	cutting, welding of pipe for connection &			
	necessary accessories as per site requirement.			
	Valve should have simple and robust connection	No		
	offering high reliability and free operation with			
	high intake capacity it should be non slam surge			
	suppression high flow combination 3 stage air			
	valve.			

Conditions:

- The attachment provided should have specifications as per schedule. 1.
- 2.
- Rate should be quoted with separate GST. The necessary training is to be provided to concerned staff. 3.

-sd-

(A.R.Kalmegh) **Executive Engineer** Mechanical Division, Satara