

कार्यकारी अभियंता,
टेंभू उपसा सिंचन यांत्रिकी व विद्युत पथक,
ओगलेवाडी, कराड यांचे कार्यालय
Ph. No. (०२१६४) २७११४२.
Email Id:- tembhumeunit@gmail.com
दि. १७/०७/२०१८.

प्रति,

मा. उपसंचालक (माहिती),
विभागीय माहिती कार्यालय,
मध्यवर्ती प्रशासकिय इमारत,
पुणे स्टेशन, पुणे.

विषय :- जाहिरात प्रसिध्दीस देणेबाबत...

महोदय,

सोबतची जोडलेली जाहिरात सातारा/कराड येथून प्रसिध्द होणाऱ्या एका मराठी वृत्तपत्रात एक वेळा प्रसिध्दीस द्यावी ही विनंती. कृपया ती नेमून दिलेल्या तारखेला किंवा तत्पूर्वी प्रसिध्दीस द्यावी ही विनंती.

- | | | |
|---|---|--|
| १ कार्यालयाचे नाव, पत्ता व दुरध्वनी क्रमांक | : | कार्यकारी अभियंता, टेंभू उपसा सिंचन यांत्रिकी व विद्युत पथक, ओगलेवाडी, कराड. पिन :- ४१५१०५, फोन नं : (०२१६४) २७११४२. |
| २ जाहिरात प्रसिध्द होण्याचा अंतिम दिनांक | : | दिनांक २३/०७/२०१८ अथवा तत्पूर्वी |
| ३ प्रसिध्दी कोणत्या स्तरावर आवश्यक (प्रादेशिक/जिल्हा पातळीवर) | : | जिल्हा स्तरावर (सातारा Region) |
| ४ जाहिरातीचे बील कोणाच्या नावे पाठवावयाचे | : | कार्यकारी अभियंता, टेंभू उपसा सिंचन यांत्रिकी व विद्युत पथक ओगलेवाडी, कराड |
| ५ जाहिरात किती वृत्तपत्रात प्रसिध्द करावयाची व किती वेळा | : | जिल्हास्तर - मराठी - एक वृत्तपत्रात (एक वेळ)
राज्यस्तर - मराठी - एक वृत्तपत्रात (एक वेळ)
राज्यस्तर - इंग्रजी - एक वृत्तपत्रात (एक वेळ) |
| ६ किती वेळा जाहिरात प्रसिध्द करावयाची आहे. | : | एकवेळ |

सोबत :- जाहिरातीच्या ४ प्रति.

कार्यकारी अभियंता,
टेंभू उपसा सिंचन यांत्रिकी व विद्युत पथक,
ओगलेवाडी, कराड.

प्रत :- मा. अधीक्षक अभियंता, यांत्रिकी मंडळ, कोल्हापूर यांना माहितीसाठी व वेबसाईट प्रसिध्दीसाठी सविनय सादर.

प्रत :- कार्यालयीन आदेश धारिका.

जलसंपदा विभाग (यांत्रिकी)

दरपत्रके- कामाचे अंदाजपत्रक तयार करणेकरिता

कार्यकारी अभियंता, टेंभू उपसा सिंचन यांत्रिकी व विद्युत पथक ओगलेवाडी, कराड दुरध्वनी ०२१६४) २७११४२ हे खाली दर्शवलेल्या कामाकरिता नोदंणीकृत कंत्राटदाराकडून व मूळ साहित्य निर्मात्याकडून कार्यालयीन कामासाठी सर्व समावेशक अंदाजपत्रकीय कार्यवाहिस्तव दरपत्रके मागविण्यात येत आहेत. संबंधीतांनी ही जाहिरात प्रसिध्द झाल्यापासून अंदाजपत्रकीय दरपत्रके दि. २३/०७/२०१८ पासून दि. ०१/०८/२०१८ पर्यंत कार्यालयीन वेळेत सादर करावीत. सदर कामाच्या बाबीचा सविस्तर तपशील www.mahayantriki.org या वेबसाईट वर उपलब्ध आहे.

अ.क्र.	तपशिल	परिणाम	दर	रुपये
१	टेंभू उपसा सिंचन प्रकल्प, टप्पा-५ वेजेगाव येथे PN- 1.6 Rating व व्यास Ø 900 mm चे डिसमेटल जाईट सह D/F Multi Door Type चे Cast Steel नॉन रिटर्न व्हॉल्व व नट-बोल्ट इ. यांची निर्मिती, पुरवठा, उभारणी, चाचणी व कार्यान्वितीकरण इ. कामासाठी सर्व खर्चासह दरपत्रक मागविणेबाबत.	५ नग		
२	टेंभू उपसा सिंचन प्रकल्प, टप्पा-५ वेजेगाव येथे PN- 1.6 Rating व व्यास Ø ११०० mm आकाराच्या बटरफ्लाय व्हॉल्वकरिता कंट्रोल पॅनेलसह actuator इ. यांची निर्मिती, पुरवठा, उभारणी, चाचणी व कार्यान्वितीकरण इ. कामासाठी सर्व खर्चासह दरपत्रक मागविणेबाबत. १) Ø ११०० mm बटरफ्लाय Actuator कंट्रोल पॅनेलसह २) Ø ११०० mm बटरफ्लाय करिता फ्लॅज (IS १५३८) ३) EPDM रबर फ्लॅज गॅसकेट OD-१४०५mm, ID-११००mm, T-६mm ४) M33x150 HT bolt, M33 HT Nut, spring washer (१ सेट) ५) M30x150 HT bolt, M30 HT Nut, spring washer (१ सेट) ६) EPDM रबर सील २५x३०x Ø ८००mm	१ सेट १ नग १ सेट १ नग १ सेट १ नग		

उपरोक्त नमुद दरपत्रके ही फ़क्त अंदाजपत्रकीय कार्यवाहीसाठी मागविण्यात येत आहेत. तसेच वरील दर हे वस्तु व सेवा कर वगळून देण्यात यावेत.

(अं.का.जाधव)

कार्यकारी अभियंता,
टेंभू उपसा सिंचन यांत्रिकी व विद्युत पथक,
ओगलेवाडी, कराड.

WATER RESOURCES DEPARTMENT (MECHANICAL)
BUDGETORY OFFER FOR ESTIMATION PURPOSE

The Budgetary offer for the below mentioned works are invited by Executive Engineer, Tembhu LIS Mech. & Ele. Unit Ogalewadi ,Karad from contractors or electrical manufacturers of the same work. The concerned contractors are requested to submit their lowest and most competitive offer to this office from date **23/07/2018 to 01/08/2018**. The work details are available for www.mahayantriki.org website.

Sr.No	Description	Qty	Rate	Amount
1	Design, Manufacturing, testing, supply ,erection and commissioning of D/F Multi door Non return Valve 900 mm diameter of PN Rating 1.6 with CFD analysis and reports conforming to IS 5312-Part 2 with material Cast Steel conforming to IS 1030 with H.T. nut bolts of required size and quantity with Dismantling Joint and its H.T. nut bolts etc. complete. including all material and labour, sundry charges , loading, unloading , third party inspection etc complete Job At Site Tembhu LIS Stage V, BhodTal: Khanapur, Dist: Sangli.	1 Job		
2 a)	Supply, Erection Testing and Commissioning of Actuator with Control panel and all other accessories required for BFV ø 1100 mm-with specifications as below 1)PN rating 1.6, Working Pressure 10 kg/cm ² , 2) Maximum working Pressure 20 kg/cm ² , 3) Differential working Pressure 20 kg/cm ² , 4) Maximum rate of flow 2900 cu.mtr/Hr. 5) Maximum Pressure in Delivery Pipe is 16 kg/cm ² and 6) Velocity in delivery pipe is 2.011 m/sec at Tembhu LIS Stage V.	1 Set		
b)	Manufacturing & providing Flanges for butterfly valve ø 1100 mm conforming to IS 1538 having following specification:- Outer Diameter – 1340mm Inner Diameter – 1124 mm Diametre of holes – 37mm Number of holes – 32 nos	1 No		
c)	EPDM rubber flange gasket having following specification:- Outer Diameter – 1405 mm Inner Diameter – 1100 mm Thickness – 6 mm	1 No.		
d)	Manufacturing & providing M33 x 150 HT bolt, M33 HT Nut, spring washer (1 set)	1 set		
e)	Manufacturing & providing M30 x 150 HT bolt, M30 HT Nut, spring washer (1 set)	1 set		
f)	Manufacturing & providing EPDM rubber seal 25mmx30mmx ø800mm	1 No		
	Total			

NOTE: Above budgetary offers are called for estimation purpose only.

(A.K.Jadhav)
Executive Engineer,
Tembhu Lift Irrigation Mechanical & Electrical Unit,
Ogalewadi – Karad.

Office of the Executive Engineer,
Tembhu Lift Irrigation Mech & Elect Unit,
Koyna Siding, Oglewadi,
Karad. Dist-Satara. Pin- 415 105.
Date: 17/ 07/2018.

To,

M/s 1) _____
2) _____
3) _____

Subject: - Regarding Budgetary Offers.

Reference:- 1) Subdivision letter TMSUVita/TS2/228/2018. Dt:-17/07/2018.

Dear Sirs,

With respect to above subject, you are requested to submit your budgetary offers for the following work of providing Neoprene Rubber Damper as per description given below for **Tembhu Lift Irrigation Stage 5, Bhoo Tal : Khanapur, Dist : Sangli.** The rates should be exclusive of GST & including of all duties, transportation, etc. The budgetary offers should be submitted to this office within **8 days** during working hours.

Sr. No	Description	Qty	Rate	Amt
1	Design, Manufacturing, testing, supply ,erection and commissioning of D/F Multi door Non return Valve 900 mm diameter of PN Rating 1.6 with CFD analysis and reports conforming to IS 5312-Part 2 with material Cast Steel conforming to IS 1030 with H.T. nut bolts of required size and quantity with Dismantling Joint and its H.T. nut bolts etc. complete. including all material and labour, sundry charges , loading, unloading , third party inspection etc complete Job At Site Tembhu LIS Stage V, BhooTal: Khanapur, Dist: Sangli.	1 Job		
2 a)	Supply, Erection Testing and Commissioning of Actuator with Control panel and all other accessories required for BFV ø 1100 mm-with specifications as below 1)PN rating 1.6, Working Pressure 10 kg/cm ² , 2) Maximum working Pressure 20 kg/cm ² , 3) Differential working Pressure 20 kg/cm ² , 4) Maximum rate of flow 2900 cu.mtr/Hr. 5) Maximum Pressure in Delivery Pipe is 16 kg/cm ² and 6) Velocity in delivery pipe is 2.011 m/sec at Tembhu LIS Stage V.	1 Set		
b)	Manufacturing & providing Flanges for butterfly valve ø 1100 mm conforming to IS 1538 having following specification:- Outer Diameter – 1340mm Inner Diameter – 1124 mm Diameter of holes – 37mm Number of holes – 32 nos	1 No		
c)	Nut bolts for above flange	1 Set		
d)	EPDM rubber flange gasket having following specification:- Outer Diameter –1405 mm Inner Diameter – 1100 mm Thickness – 6 mm	1 No.		
e)	Manufacturing & providing M33 x 150 HT bolt, M33 HT Nut, spring washer	1 set		
f)	Manufacturing & providing EPDM rubber seal 25mmx30mmx ø800mm	1 No		
	Total			

TERMS AND CONDITIONS:-

- 1) Work is to be executed at **Tembhu Lift Irrigation Stage 5, Bhod Tal : Khanapur, Dist : Sangli.**
State -MAHARSHTRA Contractor should visit the site for more details.
- 2) The rates quoted should be inclusive of all duties, Transportation, insurances, labour welfare, other relevant state/central taxes, if any, but **exclusive of GST.**
- 3) The material should be as per relevant IS/IEC specification.

Hence you are requested to furnish the lowest budgetary prices at the earliest.

Thanking you.

Yours faithfully,

(A.K.Jadhav)

Executive Engineer,
Tembhu Lift Irrigation Mechanical & Electrical Unit,
Ogalewadi – Karad.

Copy submitted to the Superintending Engineer, Mechanical Circle (C.P.), Kolhapur, for information & necessary action please. It is requested to upload this offer on official website of department.

Office Notice Board.